

DECLARATION OF PERFORMANCE

number: DoP74PKI-C_A_EN

1. Unique identification code of the product	PKI-C
2. Type	Cartridge fire damper
3. Intended use of the construction product	Fire closure for HVAC ductworks for the compartmentization
4. Name, registered trade name and contact address of the manufacturer	IMOS-Systemair, 90043 Kalinkovo 146, Slovakia
5. Where applicable, name and contact address of the authorized representative	---
6. System of assessment and verification of constancy of performance of the construction product	system 1
7. Harmonized product standard, test standard, classification standard	EN 15 650, EN 1366-2, EN 13 501-3
8. Identification number of the notified body	1396
Name and address of the notified person	FIRES s.r.o. Osloboditeľov 282, 059 35 Batizovce
Which performed in system 1:	determination of the product type on the basis of type testing (including sampling) and descriptive documentation of the production initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control
and issued certificate of constancy of performance	CE 1396-CPD-0050

9. Declared performance

Type	Dimension range (mm)	Installation*	Fire restivity
PKI-C EI60S	Ø80 up to 200	Rigid wall – wet / dry Flexible wall - wet Ceiling - wet	EI60(ve ho i ↔ o)S
PKI-C EI90S	Ø80 up to 200	Rigid wall – wet / dry Flexible wall – wet / dry Ceiling - wet	EI90(ve ho i ↔ o)S
PKI-C EI120S	Ø80 up to 200	Rigid wall – wet / dry Flexible wall – wet / dry Ceiling - wet	EI120(ve ho i ↔ o)S

* each fire damper must be installed according to installation manual PP74_PKI-C...

Supporting construction	Standard according to tab. 3 – 5 in EN 1366-2
Direction of the blade axis	vertical / horizontal
Fire resistance: maintenance of the cross section (under E) / integrity E / insulation I / smoke leakage S / mechanical stability (under E) / cross section (under E)	passed
Nominal activation conditions/sensitivity: - sensing element load bearing capacity - sensing element response temperature	passed
Response delay (resp. time) - closure time	passed
Operational reliability: - cycling manual	Passed 50 cycles
Durability of operational reliability: open and closing cycle	passed
Durability of response delay: sensing element response temperature and load bearing capacity	passed
Tightness class according to EN 1751: - casing - blade	B 2

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Kalinkovo the 26-th July 2013

 Ing. Ondrej Ertl CSc., technical director: 